



MALUHIA, A LONG TERM HEALTH CARE FACILITY

HAWAII HEALTH SYSTEMS CORPORATION

1027 Hala Drive ■ Honolulu, Hawaii 96817 ■ Telephone: (808) 832-6124 ■ Secure Fax: (808) 832-3897

April 4, 2022


TO: Interested Bidders

FROM: Scott Kawai *Scott Kawai*
Contracts Department

SUBJECT: Addendum No. 1
IFB No. 21M-0007 Maluhia – Air Conditioning Replacement for 2nd Floor

Addendum No. 1 provides clarification for the subject solicitation.

1. Question: Please see attached request for clarification on conflict between plans and specifications for material and gage of sheetmetal?



2 EQUIPMENT CURD & FLASHING DETAIL
A-3 SCALE: 3" = 1'-0"

2.01 MATERIALS

- A. All other exposed flashing and counterflashing, 20 gage zinc-coated steel, ASTM A 525, G90 hot-dip galvanized.
- B. Solder shall be 50% virgin lead and 50% pure block tin, conforming to ASTM B 32.
- C. Flux shall be non-corrosive resin type.

PART 3 – EXECUTION

3.01 INSTALLATION AND WORKMANSHIP

Maluhia
Air Conditioning Replacement For 2nd Floor

Sheet Metal Flashing and Trim
07620-1

Response: Galvanized sheet metal shall be used as called out in specifications.

2. Question: Can as-built drawings of the work area specifically power, data cabling & devices, lighting & controls, fire alarm, nurse call, speakers, etc. be provided?

Response: The facility does not have current As-Builts available of the areas called out in the drawings.

End of Addendum No. 1