



MALUHIA, A LONG TERM HEALTH CARE FACILITY
HAWAII HEALTH SYSTEMS CORPORATION

1027 Hala Drive ■ Honolulu, Hawaii 96817 ■ Telephone: (808) 832-6124 ■ Secure Fax: (808) 832-3897

April 8, 2022

TO: Interested Bidders

FROM: Scott Kawai *Scott Kawai*
Contracts Department

SUBJECT: Addendum No. 2
IFB No. 22M-0324 Maluhia – Dayroom Projects

Addendum No. 2 provides clarifications for the subject solicitation.

Addendum No. 2

From: Curtis K. Miyamura
CKM Architects, LLC
Date: April 8, 2022
Re: Drawings and Specifications for Maluhia – Hospital Dayroom Projects
1027 Hala Drive
Honolulu, Oahu, Hawaii
TMK: 1-6-009:004

Per Addendum #1, Additive Alternate No. 1 is to be deleted.

The following items are in response to RFI's or in response to items in drawings and specifications dated February 2022 that need clarifications.

1. Reference new covered deck area:
 - a. Is there a tied connection between the new concrete roof and existing concrete deck? **No.**
Noted that there is an existing gutter and downspout along the face of the existing deck? **The existing gutter and downspout to be removed.**
 - b. Please clarify extent of new painting required. All exterior concrete, including underside of new concrete deck? New fire sprinkler piping, guardrails? **Paint all exterior surfaces (1-coat primer, 2-coats finish), concrete floor shall be sealed with elastomeric deck coating, underside shall be painted with 1-coat primer. Fire sprinkler piping and guardrails painted to match existing.**

End of Addendum No. 2