



OAHU REGION

LEAHI HOSPITAL ■ MALUHIA

HAWAII HEALTH SYSTEMS CORPORATION

3675 KILAUEA AVENUE ■ HONOLULU, HAWAII 96816 ■ PHONE: (808) 733-8000 ■ FAX: (808) 733-7914

May 31, 2023

TO: Interested Parties

FROM: Scott Kawai
HHSC Oahu Region

SUBJECT: Addendum No. 3
RFP No. HHSC 23OR-0010
Contract Management/Operation of the Daniel K. Akaka State Veterans Home, State of Hawaii

Addendum No. 3 provides clarification to the subject solicitation.

1. Question: Will there be oxygen on the wall in each room?

Response: No, there are no piped medical gasses in this facility. The use of portable oxygen tanks has been accommodated with oxygen storage rooms.

2. Question: Are the negative pressure rooms ready for use and have anti-chambers/equipment?

Response: Yes, negative pressure rooms are ready for use. No, there is no antechamber. The rooms are NOT isolation rooms, but are designed to have the capability of being negative pressure.

3. Question: Are the negative pressure rooms all grouped together?

Response: Yes, the negative pressure rooms are grouped together; three (3) on each floor.