



**A LONG TERM HEALTH CARE FACILITY  
HAWAII HEALTH SYSTEMS CORPORATION**

---

1027 Hala Drive ■ Honolulu, Hawaii 96817 ■ Telephone: (808) 832-6124 ■ Secure Fax: (808) 832-3897

February 26, 2026

TO: Interested Bidders

FROM: Michael Nakada  
HHSC Oahu Region

SUBJECT: Addendum No. 2  
IFB No. 26M-0201 Maluhia Cooling Tower Replacement

---

Addendum No. 2 provides clarification to the subject solicitation.

Please see attached.

End of Addendum No. 2



MECHANICAL ENTERPRISES, INC.  
MECHANICAL & FIRE PROTECTION ENGINEERS  
501 SUMNER STREET, SUITE 503 · HONOLULU, HAWAII · 96817  
Phone: (808) 591-9038 · Fax: (808) 596-7356

## ADDENDUM NO.2

---

### MALUHIA HOSPITAL COOLING TOWER REPLACEMENT

1207 Hala Drive  
Honolulu, Hawaii 96817  
Maluhia Hospital

---

The items listed herein are hereby made a part of the contract for the above project and shall govern the work, taking precedence over the previously issued plans and specifications governing the items mentioned. All new work specified by this Addendum shall conform to the basic drawings and specifications.

---

### REQUEST FOR INFORMATION

1. General Notes #8: Item #8 states to install Sealant at all weather joints, whether shown or not on drawings. Please confirm contractor is not required to install sealant on any existing weather joints that are not being modified.
  - a. Response: Contractor is not required to install sealants on any existing weather joints that are not being modified.
2. Is the Condenser Water pump on VFD?
  - a. No, condenser water pumps are on soft starters.
3. Will there be revised drawings submitted to show the correct chilled water pump being removed?
  - a. Yes, revised drawings will be submitted to show the correct chilled water pump being removed.

## ADDENDUM NO.2

---

MALUHIA HOSPITAL COOLING TOWER REPLACEMENT  
1207 Hala Drive  
Honolulu, Hawaii 96817  
Maluhia Hospital

Sheet 1 of 1

February 25, 2026