



MALUHIA, A LONG TERM HEALTH CARE FACILITY
HAWAII HEALTH SYSTEMS CORPORATION

1027 Hala Drive ■ Honolulu, Hawaii 96817 ■ Telephone: (808) 832-6124 ■ Secure Fax: (808) 832-3897

August 17, 2017

TO: Interested Bidders

FROM: Michelle Kato *Michelle Kato*
Contract Manager

SUBJECT: IFB No. HHSC FY 18-001
Maluhia Reflooring
Addendum No. 1

This is an Addendum to address the RFI questions.

- 1) Please advise if scope of work is to skim over all the existing tile?
Response: Yes the project is to install the new vinyl plank flooring over the existing floor and if necessary, smooth out the existing floor as needed.
- 2) Is contractor responsible to move and reinstall all the furniture?
Response: No, contractor is not responsible for moving furniture.
- 3) Please advise if existing tile has asbestos.
Response: No existing tile does not contain asbestos.
- 4) Is scope of work to demo existing floor and install new flooring or install new flooring over the existing floor?
Response: Install new flooring over the existing floor.
- 5) Please confirm no bid bond needed.
Response: No bid bond is required.
- 6) Does the labor quote need to be follow the Davis Bacon or Hawaii State Wage Rate, or not?
Response: State prevailing wages are required.
- 7) Can I substitute the Island Koa with the 20 mil. LVT (Curly Koa) ?
Response: Yes, this is an approved substitute.

End of Addendum No. 1